



ADDENDUM NO. 02

VAMC Durham
Durham, North Carolina

VAMC Durham – Outpatient Care Building 17
Contract No.: VA246-13-C-0118
April 27, 2015

This addendum modifies the Contract Documents dated December 12, 2015, only in the manner and to the extent stated herein and shown on any accompanying drawings and specifications as Addendum No. #02 dated April 27, 2015, and will become a part of the Contract Documents. Except as specified or otherwise indicated by this Addendum, all work shall be in accordance with the basic requirements of the Contract Documents. Acknowledgment of the Addendum shall be noted on the bid form.

The following is a list of drawing revisions for the above referenced project:

Item No.	Drawing No.	Add Remove Revise Clarification	Direction:
1.	ET-701	Added	Added notes for integration with existing campus CCTV Video Surveillance System, Panic/Duress System, Nurse Call System and Access CONTROL Systems.
2.	F-001	Revise	Add Fire Alarm Response Matrix
3.	F101	Revise	Add Smoke, Heat Detection, addressable relays for Elevator Equip & Lobby
4.	F012	Revise	Add Elevator Lobby Smoke Detector

END

AVETECH DESIGN GROUP plc

123 Bruton Court, Suite 100
Chesapeake, VA 23322
Phone: 757.389.5518
Fax: 757.389.5207

www.avetechdg.com

